



November 19, 2012

VAN GOETHEM SEPTIC SYSTEMS, INC.
CONCRETE DEPT.
LONNY VAN GOETHEM
EAST 3055 COUNTY HWY J
KEWAUNEE WI 54216

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: VAN GOETHEM SEPTIC SYSTEMS, INC.
Product Name: SEPTIC, HOLDING, OR PUMP
Model Number(s): 1260
(45" L.L., 29.5 GAL/IN., 42" MAX. DEPTH OF BURY, 635 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20120350

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of APRIL 2017.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Opening cast in riser for electrical wiring.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Pipe materials constructed in conformance with Table SPS 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank wall.
 - "Cast-A-Seal" by Press Seal Gasket Corp.
 - Polypropylene riser and access cover by EZ Set Tank Company
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- **AS OF MARCH 1, 2009, SECTION SPS 384.10 (FORMERLY COMM 84.10) WAS MODIFIED AND THE REVIEW OF EXTERIOR GREASE INTERCEPTORS AS A PLUMBING PRODUCT IS NO LONGER REQUIRED. REVIEW WILL BE CONDUCTED AT THE TIME OF PROJECT-SPECIFIC PLAN REVIEW.**

This approval supersedes the approval issued on 4/25/2012 under product file number 20070070.

VAN GOETHEM SEPTIC SYSTEMS, INC.

Page 2

November 19, 2012

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070070..

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones

Public Swimming Pool Plan / Plumbing Product Reviewer

phone: (608) 267-5265

fax: (608) 266-2602

email: glen.jones@wi.gov